

Laboratory Report

CLIENT: Village of Malone
PROJECT: PWS 1600008, PbCu x9

WORK ORDER: 2309-28014
DATE RECEIVED: 9/11/23

001	Site: 27 Bigelow St			Date Sampled:	9/6/23	Time:	7:20
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.097	mg/L	EPA 200.8	9/21/23 16:27	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 16:27	W RSB	A	

002	Site: 94 Murray St			Date Sampled:	9/1/23	Time:	3:50
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	9/21/23 16:42	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 16:42	W RSB	A	

003	Site: 283 Lower Park St			Date Sampled:	9/7/23	Time:	7:00
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.025	mg/L	EPA 200.8	9/21/23 16:47	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 16:47	W RSB	A	

004	Site: 29 3rd Street			Date Sampled:	9/5/23	Time:	10:20
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.058	mg/L	EPA 200.8	9/21/23 16:52	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 16:52	W RSB	A	

005	Site: 24 Barbara St			Date Sampled:	9/5/23	Time:	5:00
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.061	mg/L	EPA 200.8	9/21/23 16:57	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 16:57	W RSB	A	

006	Site: 2 Reservoir St			Date Sampled:	9/1/23	Time:	6:00
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.065	mg/L	EPA 200.8	9/21/23 17:02	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 17:02	W RSB	A	

007	Site: 10 Williamson St			Date Sampled:	9/1/23	Time:	11:15
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	9/21/23 17:07	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 17:07	W RSB	A	

008	Site: 29 Barbara St			Date Sampled:	9/3/23	Time:	14:30
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.044	mg/L	EPA 200.8	9/21/23 17:12	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 17:12	W RSB	A	

Laboratory Report

CLIENT: Village of Malone
 PROJECT: PWS 1600008, PbCu x9

WORK ORDER: **2309-28014**
 DATE RECEIVED: 9/11/23

009	Site: 28 Barbara St	Date Sampled: 9/1/23	Time: 19:15
-----	---------------------	----------------------	-------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	0.052	mg/L	EPA 200.8	9/21/23 17:17	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/21/23 17:17	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Laboratory Report

CLIENT: Village of Malone
 PROJECT: PWS 1600008, PbCu x4

WORK ORDER: **2309-29063**
 DATE RECEIVED: 9/14/23

001	Site: 6 Harding St				Date Sampled:	9/11/23	Time:	18:00
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
Copper, Total	0.14	mg/L	EPA 200.8	9/27/23 19:39	W RSB	A		
Lead, Total	0.0040	mg/L	EPA 200.8	9/27/23 19:39	W RSB	A		

002	Site: 15 College Ave				Date Sampled:	9/11/23	Time:	5:42
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
Copper, Total	0.037	mg/L	EPA 200.8	9/27/23 19:44	W RSB	A		
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/27/23 19:44	W RSB	A		

003	Site: 171 Low Rd				Date Sampled:	9/11/23	Time:	16:00
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
Copper, Total	< 0.020	mg/L	EPA 200.8	9/27/23 19:49	W RSB	A		
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/27/23 19:49	W RSB	A		

004	Site: 226 Webster St				Date Sampled:	9/14/23	Time:	7:00
<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>	
Copper, Total	0.056	mg/L	EPA 200.8	9/27/23 19:54	W RSB	A		
Lead, Total	< 0.0010	mg/L	EPA 200.8	9/27/23 19:54	W RSB	A		

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Laboratory Report

CLIENT: Village of Malone
 PROJECT: PWS 1600008, PbCu

WORK ORDER: **2309-29637**
 DATE RECEIVED: 9/21/23

001 Site: 14 South Street Date Sampled: 9/18/23 Time: 4:24

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/3/23 13:40	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/3/23 13:40	W RSB	A	

002 Site: 92 Constable Street Date Sampled: 9/18/23 Time: 4:20

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	0.034	mg/L	EPA 200.8	10/3/23 13:55	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/3/23 13:55	W RSB	A	

003 Site: 13 Webb Ave Date Sampled: 9/19/23 Time: 7:00

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	0.031	mg/L	EPA 200.8	10/3/23 14:00	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/3/23 14:00	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Laboratory Report

CLIENT: Village of Malone
PROJECT: PWS 1600008, PbCu

WORK ORDER: 2310-30996
DATE RECEIVED: 9/28/23

001	Site: 119 William St	Date Sampled: 9/23/23	0:00				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 20:27	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:27	W RSB	A	
002	Site: 42 Third St	Date Sampled: 9/26/23	Time: 5:45				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.11	mg/L	EPA 200.8	10/19/23 20:32	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:32	W RSB	A	
003	Site: 35 Fourth St	Date Sampled: 9/26/23	Time: 7:30				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.080	mg/L	EPA 200.8	10/19/23 20:37	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:37	W RSB	A	
004	Site: 10 Sprague St	Date Sampled: 9/26/23	Time: 6:00				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.16	mg/L	EPA 200.8	10/19/23 20:42	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:42	W RSB	A	
005	Site: 79 Pearl St	Date Sampled: 9/26/23	Time: 6:00				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 20:47	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:47	W RSB	A	
006	Site: 9 Coffee	Date Sampled: 9/26/23	0:00				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.029	mg/L	EPA 200.8	10/19/23 20:52	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 20:52	W RSB	A	
007	Site: 3 Lane St	Date Sampled: 9/21/23	Time: 6:30				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 21:12	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 21:12	W RSB	A	
008	Site: 913 Cty Rt 25	Date Sampled: 9/27/23	Time: 13:23				
Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Copper, Total	0.41	mg/L	EPA 200.8	10/19/23 21:27	W RSB	A	
Lead, Total	0.0159	mg/L	EPA 200.8	10/19/23 21:27	W RSB	A	

Laboratory Report

CLIENT: Village of Malone
PROJECT: PWS 1600008, PbCu

WORK ORDER: **2310-30996**
DATE RECEIVED: 9/28/23

009 Site: 36 Willow St Date Sampled: 9/18/23 Time: 8:00

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 21:32	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 21:32	W RSB	A	

010 Site: 46 Rockland St Date Sampled: 9/28/23 Time: 6:30

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 21:37	W RSB	A	
Lead, Total	0.0115	mg/L	EPA 200.8	10/19/23 21:37	W RSB	A	

011 Site: 92 Franklin St Date Sampled: 9/28/23 Time: 7:00

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	0.035	mg/L	EPA 200.8	10/19/23 21:42	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 21:42	W RSB	A	

012 Site: 2 Howard Dr Date Sampled: 9/28/23 Time: 8:00

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 21:47	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 21:47	W RSB	A	

013 Site: 95 Park St Date Sampled: 9/28/23 Time: 6:00

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/19/23 21:52	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/19/23 21:52	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.

Laboratory Report

CLIENT: Village of Malone
 PROJECT: PWS 1600008, PbCu

WORK ORDER: **2310-31007**
 DATE RECEIVED: 9/29/23

001	Site: 31 Webb Ave	Date Sampled: 9/29/23	Time: 7:30
-----	-------------------	-----------------------	------------

<u>Parameter</u>	<u>Result</u>	<u>Units</u>	<u>Method</u>	<u>Analysis Date/Time</u>	<u>Lab/Tech</u>	<u>NELAC</u>	<u>Qual.</u>
Copper, Total	< 0.020	mg/L	EPA 200.8	10/18/23 14:37	W RSB	A	
Lead, Total	< 0.0010	mg/L	EPA 200.8	10/18/23 14:37	W RSB	A	

Test results comply with all NELAC requirements unless otherwise noted. This Laboratory Report includes the client's COC sample documentation and shall not be reproduced except in full, without written approval of the laboratory.